



**TÜVRheinland®**

**ZERTIFIKAT  
CERTIFICATE**

**No.: 968/EZ 442.00/10**

<b>Product tested</b>	Gas Detector Series SafEye 700S	<b>Licence holder</b>	Spectrex Inc. 218 Little Falls Rd. Cedar Grove, NJ 07009 USA
<b>Type designation</b>	SafEye 701S, 702S, 703S, 721S, 722S, 723S		
<b>Codes and standards forming the basis of testing</b>	IEC 61508 Parts 1-7:1998 / 2000 EN 50402:2005 + A1:2008 EN 50270:2006 EN 50271:2001		
<b>Intended application</b>	Detectors of the gas detector series SafEye 700S can be used for the detection of ambient combustible gases.  The gas detector series SafEye 700S complies with the requirements of the relevant standards (SIL 2 acc. to IEC 61508) and can be used in applications up to SIL 2 acc. to IEC 61508.		
<b>Specific requirements</b>	The instructions of the associated User's and Maintenance Manual shall be considered.		
This certificate is valid until 2015-05-20.			



The test report-no.: 968/EZ 442.00/10 dated 2010-05-20 is an integral part of this certificate.

The holder of a valid licence certificate for the product tested is authorized to affix the test mark shown opposite to products, which are identical with the product tested.

**TÜV Rheinland Industrie Service GmbH**  
**Geschäftsfeld ASI**

Automation, Software und Informationstechnologie

Am Grauen Stein, 51105 Köln

Postfach 91 09 51, 51101 Köln

Köln, 2010-05-20

Certification Body of  
TÜV Rheinland Industrie Service GmbH

Dipl.-Ing. Stephan Häb